

PUNJAB STATE ELECTRICITY REGULATORY COMMISSION
SITE NO. 3, BLOCK B, SECTOR 18-A MADHYA MARG, CHANDIGARH

Petition No. 59 of 2023
Date of Hearing: 24.01.2024
Date of Order: 30.01.2024

Filing Petition under Section 86 (1) (B) of the Electricity Act, 2003 and PSERC Regulation 9.14.

In the matter of: Punjab State Power Corporation Limited (PSPCL), The Mall, Patiala, Punjab

.....Petitioner

Commission: Sh. Viswajeet Khanna, Chairperson
Sh. Paramjeet Singh, Member

PSPCL: Ms. Harmohan Kaur, CE/ARR&TR
Sh. Gurpreet Singh, ASE/GHTP
Sh. Maninder Singh, Sr.Xen/Planning
Sh. Ajay Bansal, DY.CE/TR-II

ORDER

The petition was fixed for hearing on admission and PSPCL was intimated to provide additional information. PSPCL has provided the information vide memo No. 5093 dated 23.01.2024. However, the information is not comprehensive and detailed and PSPCL is directed to provide further information as under:

1. As per MoM of PSPCL Committee dated 23.12.2022 the balance life of the unit has been shown to be 4 years and 1 month with a note that as per CEA guidelines, the life of unit can be extended by another 15-20 years beyond its original 25 years after conducting a Residual Life Assessment (RLA) study and carrying out requisite R&M activities. PSPCL should submit the expected balance extended life of GHTP Stage-1 Units, which is currently more than 23 years old, supported by the required RLA study.
2. PSPCL to provide the latest status of the work.
3. PSPCL to submit the estimated life extension, improvement in performance parameters etc. in line with Regulation 9.10 of the PSERC MYT Regulations 2022.

The above information be provided within two weeks (through hard copy & soft copy). The petition shall be taken up for hearing on admission on 20.03.2024 at 11.30 AM.

Sd/-
(Paramjeet Singh)
Member

Sd/-
(Viswajeet Khanna)
Chairperson

Chandigarh
Dated:**30.01.2024**