

PUNJAB STATE ELECTRICITY REGULATORY COMMISSION
SITE NO. 3, BLOCK B, SECTOR 18-A MADHYA MARG, CHANDIGARH

Petition No. 26 of 2019
Date of Hearing: 11.12.2019
Date of Order: 16.12.2019

Petition for seeking permission to extend the time for 9 months from the submission of test report dated 12.06.2019 to 12.03.2020 for the completion of Double Circuit of 66 KV line from 220 KV S/Stn. G-1 MGG to 66 KV S/Stn. Focal Point Mandi-Gobindgarh for release of new LS Induction furnace connection to M/s Dev Bhoomi Casting Pvt. Ltd. Village kumbra road, Transport Nagar, Mandi Gobindgarh.

In the matter of: Punjab State Power Corporation Limited., The Mall,
Patiala.

Petitioner

Versus

M/s Dev Bhoomi Casting Pvt. Ltd. Village Kumbra road,
Transport Nagar, Mandi Gobindgarh.

Respondent

Present: Ms. Kusumjit Sidhu, Chairperson
Sh. S.S. Sarna, Member
Ms. Anjali Chandra, Member

PSPCL: Sh. Bhupinder Sharma, C.E/ARR&TR
Sh. V.P.S Kailay, SE/TR-2
Sh. Mukesh Kumar, ASE/TR-5
Sh. Loveleen Garg/AEE-TR-5
Sh. Deepak Goel, Sr.Xen
Sh. Bipin Dhingra, RA, MGG

Dev Bhoomi
Casting Pvt Ltd: None

ORDER

Punjab State Power Corporation Limited (PSPCL) had filed the present petition submitting that M/s Dev Bhoomi Casting Pvt. Ltd applied for a new connection vide RID No. 19938 for LS connection load 3600KW/4000KVA CD on 30.08.2019. The CE/Commercial, Patiala cleared the feasibility vide memo no. 166/SWS/RID no. 19938 dated 28.01.2019 with the condition that the connection would be released after commissioning of the 4th 100MVA, 220/66Kv transformer at 220Kv S/Stn. G-1 MGG and completion of Double Circuit of 66 Kv line from 220 Kv S/Stn. G-1 MGG to 66 KV S/Stn. Focal Point MGG. M/s Dev Bhoomi Casting Pvt. Ltd. submitted the

test report which has been entered in SAP system on 12.06.2019 in the office of AEE/Commercial, Sub Division, PSPCL, Mandi Gobindgarh. During the installation of Double Circuit of 66 Kv line from 220 Kv S/Stn. G-1 MGG to 66 KLV S/Stn. Focal Point MGG, it was realised that the process of installation may take around 9 months. Therefore, permission had been sought for grant of extension of time upto 12.03.2020 for the release of the new large supply connection to M/s Dev Bhoomi Casting Pvt. Ltd. Village Kumbra road Transport Nagar, Mandi Gobindgarh.

However, PSPCL has now filed a revised Feasibility Clearance vide memo no. 6092 dated 10.12.2019. It has been submitted during the hearing that the condition of completion of double circuit 66 KV line from 220 KV sub-station G-1, MGG to 66 KV sub-station focal point Mandi Gobindgarh in the previously granted feasibility to M/s Dev Bhoomi Casting Pvt. Ltd. has been waived off. This is because an applicant seeking connection prior to Dev Bhoomi has requested that his application be cancelled. On checking of the feeding station i.e. 66 KV S/Stn. Focal Point MGG it was observed that load can be released after load balancing on the T/F of this S/Stn. Sr. Xen/DS Special Division Mandi Gobindgarh has confirmed that space for 11 kV Breaker is available at 66KV S/Stn. Focal Point MGG and thus the connection to Dev Bhoomi Casting Pvt. Ltd can be released without any delay.

In view of the above no cause of action survives in the petition and the petition is disposed off accordingly.

Sd/-
(Anjali Chandra)
Member

Sd/-
(S.S. Sarna)
Member

Sd/-
(Kusumjit Sidhu)
Chairperson

Chandigarh
Dated: **16.12.2019**