

PUNJAB STATE ELECTRICITY REGULATORY COMMISSION
SCO 220-221, SECTOR 34-A, CHANDIGARH

Public Notice

Mithila Malleables Private Limited, G.T. Road, Sirhind has filed a petition with the Commission praying for removal of anomaly in the restricted load of arc furnaces and induction furnaces during peak load hours.

To mitigate the problem of induction furnace consumers, Commission proposes to make an amendment in clause 49.2(ii)c of the Conditions of Supply as under:

Existing clause	Proposed clause
Induction furnace consumers: 5% of sanctioned Contract Demand or 50 KW per furnace, whichever is less.	Induction furnace consumers: 2.5% of sanctioned Contract Demand or 50 KW per furnace whichever is more.

The comments/suggestions of the stakeholders on the proposal are invited so as to reach the Commission by 12th November, 2012. The Commission shall also be holding a public hearing in the matter on 15th November, 2012 at 11.30 AM in the office of the Commission.

Sd/-
SECRETARY